

 MAHARASHTRA NATURAL GAS LIMITED	Tender for Supply, Installation & Commissioning of Voltage Stabilizer (Servo Liner Type) at CNG stations of MNGL, Pune. BID NO. MNGL/C&P/2019-20/32
---	--

Date: 28.05.2019

Replies to Queries of the Bidders-III

SUB: Replies to queries of the bidders' against Tender for Supply, Installation & Commissioning of Voltage Stabilizer (Servo Liner Type) at CNG stations of MNGL, Pune.

REF: Bid Document No. MNGL/C&P/2019-20/32 dated 10.05.2019

Dear Sir,

Following are the replies to queries of the bidders'. Kindly note the same.

Sr. No.	Bidder's Query / Clarification	MNGL's Reply
1.	Regarding S.No. 3: in which you have asked for Bypass Switch: In same, kindly suggest if you want Changeover switch or electrical Bypass switch. Also please specify the Make of Bypass Switch, so that we can quote accordingly.	Changeover Switch is required of the following makes ABB, Schneider or L&T.

Shekhar D Kankrej
Dy. Manager (C&P)