

 MAHARASHTRA NATURAL GAS LIMITED	Tender for Supply, Installation & Commissioning of Voltage Stabilizer (Servo Liner Type) at CNG stations of MNGL, Pune. BID NO. MNGL/C&P/2019-20/32
---	--

Date: 20.05.2019

Replies to Queries of the Bidders

SUB: Replies to queries of the bidders' against Tender for Supply, Installation & Commissioning of Voltage Stabilizer (Servo Liner Type) at CNG stations of MNGL, Pune.

REF: Bid Document No. MNGL/C&P/2019-20/32 dated 10.05.2019

Dear Sir,

Following are the replies to queries of the bidders'. Kindly note the same.

Sr. No.	Bidder's Query / Clarification	MNGL's Reply
1.	Please clarify technical query regarding Isolation Transformer require in -Built or External & also confirm not require with SCVS.	Only Servo Controlled Voltage Stabilizer (SCVS). No Isolation Transformer to be provided.
2.	With reference to the tender specifications, demanded warranty 60 Months & as per OEM standard 2 Years Warranty on SCVS. Request to you please provide us for quoting tender with 2 Years warranty & 10% PBG Against this order. For extended warranty we can mention AMC cost for next Three Years. OR REFERENCE TOTENDER , PLS NOTE YOU HAVE ASKED 10% BANK GUARANTEE OF TOTAL AMOUNT FOR APPROX. 6 YEARS , PLS NOTE MAXIMUM BANK GUARANTEE IS OF 1.5 YEAR FOR EVERY TENDER , SO IT'S A REQUEST TO PLS TAKE BANK GUARANTEE OF 1 YEAR ONLY	Tender Conditions Prevails. For Guarantee refer the Clause No 20 of General Conditions of Contracts of tender document. For Performance Bank Guarantee refer the clause No 12 of General Conditions of Contract of tender document.

Shekhar D Kankrej
Dy. Manager (C&P)