 MAHARASHTRA NATURAL GAS LIMITED	REPLY TO BIDDERS QUERIES – II AGAINST TENDER FOR ANNUAL RATE CONTRACT FOR PROCUREMENT OF SMART MRS FOR CGD NETWORK OF MNGL, PUNE Bid No.: MNGL/C&P/2019-20/69
---	--

Date: 14.08.2019

Replies to Queries of the Bidders - II


SUB: Replies to queries of the bidders – II for Tender for annual rate contract for procurement of Smart MRS for CGD Network of MNGL, Pune

REF: Bid Document No. MNGL/C&P/2019-20/69 dated 02.08.2019 & Reply to bidders queries dated 12.08.2019

Dear Sir,

Following are the replies to queries of the bidders. Kindly note the same.

Sl. No.	Bidder's Query / Clarification	MNGL' Reply
1	Outlet Pressure is higher than Inlet pressure. MNGL to confirm below confirmation to clear as a part scope of supply: <ol style="list-style-type: none"> 1. Min DP across the skid. 2. Specific Line pressure to be considered for inlet line size. 3. Specific line pressure to be considered for outlet line size. 4. Specific line pressure to be considered for Meter size. 	1) Min DP across the skid- As per the process calculations. 2) Specific Line pressure to be considered for inlet line size- Minimum pressure of 2 bar to be considered. 3) Specific line pressure to be considered for outlet line size- 2 Bar. 4) Specific line pressure to be considered for Meter - Minimum pressure of 2 bar to be considered. All the sizing shall be done as per velocity parameters as specified in T4S standards of PNGRB guidelines.
2	We understand from process parameter that skid design will be of 150# however tender P&ID shows 300#. You are requested to kindly confirm we need to follow skid design 150# or 300#.	Skid design shall be as per 150#

 <p>MAHARASHTRA NATURAL GAS LIMITED</p>	<p>REPLY TO BIDDERS QUERIES – II AGAINST TENDER FOR ANNUAL RATE CONTRACT FOR PROCUREMENT OF SMART MRS FOR CGD NETWORK OF MNGL, PUNE</p> <p>Bid No.: MNGL/C&P/2019-20/69</p>
---	---

Please submit the signed & stamped copy of Replies to Queries of the Bidders – II along with tender document with your techno-commercial offer as a token of acceptance.

All the others terms and conditions of the bid documents are unchanged.

With regards.

Ganesh Said
Sr. Manager (C&P)