

 MAHARASHTRA NATURAL GAS LIMITED	Tender for Supply, Installation & Commissioning of Voltage Stabilizer (Servo Liner Type) at CNG stations of MNGL, Pune. BID NO. MNGL/C&P/2019-20/32
---	--

Date: 24.05.2019

Replies to Queries of the Bidders-II

SUB: Replies to queries of the bidders' against Tender for Supply, Installation & Commissioning of Voltage Stabilizer (Servo Liner Type) at CNG stations of MNGL, Pune.

REF: Bid Document No. MNGL/C&P/2019-20/32 dated 10.05.2019

Dear Sir,

Following are the replies to queries of the bidders'. Kindly note the same.

Sr. No.	Bidder's Query / Clarification	MNGL's Reply
1.	Bidder requests for unbalanced type voltage stabilizer instead of balanced type voltage stabilizers as per tender document.	Tender conditions prevail. Balanced type SCVS is required for MNGL.
2.	Referring to Section - V (Special Conditions of Contract), you have requested output voltage as 415 V in tender, we request you to change output voltage from 415 V to 400 V as it has been observed that electrical equipments gives optimum efficiency at 400V. So we suggest you to maintain voltage of 400 Volts in stabilizer, which will help you save substantial cost of electricity Please note that the AVC output can be adjusted up or down by ~15 to 20 Volts albeit with a corresponding shift in the input voltage range.	Tender conditions prevail.
3.	Bypass Change Switch require along with SCVS or provided by MNGL externally. Please confirm.	Bypass switch is required and shall be in the scope of Contractor / Vendor.
4.	We are requesting you to extend the date of submitting the tender.	Accepted. 1) DUE DATE OF SUBMISSION OF BID: 31.05.2019 upto 15:00 hrs. 2) TECHNO-COMMERCIAL BID OPENING DUE DATE & TIME: 31.05.2019 at 16:00 Hrs.

Shekhar D Kankrej
Dy. Manager (C&P)